

क्रमांक - 367

भाग - 3

2

16/5/2024

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 12/04/2024

It is certified that an inspection team headed by Lalit Kumar (S.A.) & Jitendra Kr.

(Name of Officers with designation) from U.P. Jal Nigam (R) PHED

inspected the Holy Public School, Sigma-1 Greater Noida (UP)

(Name & Address of the school) on 09/04/2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. C/6573/1/2024 dated 12/04/2024

of U.P. Jal Nigam (R) G.B. Nagar (PHED Lab) certified that the

Holy Public School, G.T. Noida (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till one year.....

Signature with Seal:

Name

Designation

Name & Address of the Office / Department

Mahendra Kumar
15/04/2024

Mahendra Kumar
Assistant Engineer

U.P. Jal Nigam (R)
G.B. Nagar

Uttar Pradesh
Ghazabad

To Holy Public School,
Sigma-1 Greater Noida (UP)
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

65 | Page



[Signature]
Manager
Holy Public School

Gr. Noida



TEST REPORT

District Level Water Analysis Laboratory

Address: Badalpur Water Supply Scheme, Near polytechnic college
Village- Badalpur, Distri:- Gautam Buddha Nagar- 203207



Report No	C/6573/1/2024		Issue Date	12-04-2024
Customer Details				
Office Name and Address	HOLY PUBLIC SCHOOL, SIGMA-I GREATER NOIDA (UP)			
Ref Letter No & Date	H/April/2024/IPSIGN/W.Cer & 03-04-2024			
Basic details of sample				
District	G.B. NAGAR	Village/Town	SIGMA-I(Greater Noida)	
Location	HOLY PUBLIC SCHOOL, GARDEN AREA SIGMA-I GREATER NOIDA (UP)			
Water Source	R O	Sample No.	6573	
Quantity of Sample	1000 ml	Date of Collection	09-04-2024	
Receiving Date	09-04-2024	Sample Collector	Mr. Lalit Kumar	
Sample Depositor,	Mr. Lalit Kumar	Sampling Method	IS 17614(PART 1): 2021	
Analysis Start Date	10-04-2024	Analysis Completion Date:	12-04-2024	

Technical Data of Analysis						
S. No.	Analyzed Parameter	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Reference Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH temp.(25°)	-	7.45	6.5-8.5	No Restriction	IS 3025 (Part 11):2022
2	Turbidity	NTU	0.98	1.00	5.00	IS 3025 (Part 10): 2023
3	Total Dissolved Solids	mg/L	107	500	2000	IS 3025 (Part 16): 2023
4	Chloride as Cl	mg/L	12	250	1000	IS 3025 (Part 32):2019
5	Total Alkalinity as CaCO3	mg/L	80	200	600	IS 3025 (Part 23):2023
6	Total Hardness as CaCO3	mg/L	64	200	600	IS 3025 (Part 21): 2019
7	Sulphate as SO4	mg/L	10.58	200	400	APHA 24 th edition- 4500- SO4 ²⁻
8	Nitrate as NO3	mg/L	2.62	45	No Restriction	APHA 24 th edition- 4500- NO3 ⁻
9	Calcium as Ca	mg/L	11.2	75	200	IS 3025 (Part 40): 2023
10	Magnesium as Mg	mg/L	8.64	30	100	IS 3025 (Part 46):2023
11	Odour	Qualitative	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2018
12	Color	HU	<1	5	15	IS 3025 (Part 41): 2021
13	Iron as Fe	mg/L	0.121	1.0	No Restriction	APHA 24 th edition- 3500- Fe B
14	Fluoride as F-	mg/L	0.164	1.0	1.5	APHA 24 th edition- 4500- F- C

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days from the date of issue of tests reports unless otherwise specified.

Prepared By
LAR ASSISTANT
District Level Water Analysis Laboratory
(Deputy Field Officer), Gautam Buddha Nagar



Manager
Holy Public School
Gr. Noida